

1. AVOIDANCE CONDITION FOR AREA SOURCES SUBJECT TO 40 CFR 63 Subpart JJJJJ (6J) – In accordance with 15A NCAC 2Q .0317, the Permittee is avoiding applicability of 40 CFR 63 Subpart JJJJJ (6J) "Industrial, Commercial, and Institutional Boilers Area Sources".

The Permittee is permitted to operate a natural gas / No. X [Specify fuel oil #] fuel oil-fired boiler (ID Nos. XXX [specify source ID Nos]). Per 40 CFR 63.11195(e), these/this source(s) is/are exempt from this Subpart because it is/they are defined as a/as gas-fired boiler(s). In order to maintain this exemption, the Permittee is allowed to fire liquid fuel only during periods of gas curtailment, natural gas emergencies, or periodic testing on liquid fuel (periodic testing not to exceed a combined total of 48 hours during any calendar year).

The Permittee shall maintain records that document the time periods when liquid fuel is fired and the reasons the liquid fuel is fired.

If the Permittee fires liquid fuel for reasons other than gas curtailment, natural gas emergencies, or periodic testing on liquid fuel, the Permittee is no longer exempt from Subpart JJJJJ (6J), and must be in compliance **as a new source** upon startup (commencement of firing of the liquid fuel).